

# DECLARATION OF PERFORMANCE



No. 921163400\_59\_004

7. Unique identification code of the product-type: BS-1634
  
8. Intended use/es: 4 zones conventional fire alarm control panel for use in fire detection and fire alarm systems installed in buildings.
  
9. Manufacturer: Olympia Electronics N. Lakasas – P. Arvanitidis S.A. 72nd klm Old national road Thessaloniki – Katerini, Kolindros, Pieria, Greece P.O. 60061
  
10. System/s of AVCP: System 1
  
11. Harmonized standard: EN 54-2:1997 +A1:2006 Fire detection and fire alarm systems – Part 2: Control and indicating equipment  
  
EN 54-4: 1997 +A1:2002 +A2:2006 Fire detection and fire alarm systems – Part 4: Power supply equipment  
  
Notified body/ies: HELLENIC ELECTRONIC EQUIPMENT QUALITY ASSURANCE CENTER, No. 0848

**Headquarters:** 72 km Old Highway Thessaloniki Katerini, Postal code 60 300, P.O.Box 06, Eginio - Pieria - Greece  
T. +30 23530 51200 | F. +30 23530 51486 | info@olympia-electronics.gr

**Athens Branch:** 18 Leontariou street, Kantza, Postal code 15351 Pallini, Greece  
T. +30 210 985 2193-4 | F. +30 210 985 2225 | athens@olympia-electronics.gr

[www.olympia-electronics.gr](http://www.olympia-electronics.gr)

12. Declared performance/s:

Essential characteristics	Performance	Harmonised technical specification:		
		EN 54-2:1997 +A1:2006	EN 54-4:1997 +A1:2002 +A2:2006	Comments
Operational reliability	PASS	4 <sup>a</sup> , 5 <sup>a</sup> , 6 <sup>a</sup> , 7 <sup>a</sup> , 8 <sup>a</sup> , 9 <sup>a</sup> , 12 <sup>a</sup> , 13 <sup>a</sup> , 14 <sup>a</sup>	4 <sup>b</sup> , 5 <sup>b</sup> , 6 <sup>b</sup> , 7 <sup>b</sup> , 8 <sup>b</sup>	a, b
Durability of operational reliability: Temperature resistance	PASS	15.4	9.5	
Durability of operational reliability: Vibration resistance	PASS	15.6, 15.7, 15.15	9.7, 9.8, 9.15	
Durability of operational reliability: Humidity resistance	PASS	15.5, 15.14	9.7, 9.8, 9.15	
Durability of operational reliability: Electrical stability	PASS	15.8 to 15.13	9.9 to 9.13	
Response delay (response time to fire)	PASS	7.1, 7.7, 7.11, 7.12		a
Performance under fire conditions	PASS	4, 5, 7		a, b
Performance of power supply	PASS		4, 5, 6	b

Comments:

a) The product has been certified with the available options with requirements of the harmonized technical specification **EN 54-2:1997 +A1:2006** which are mentioned below.

7.8 Output to fire alarm devices

7.11 Delays to outputs

b) The product covered by the standards that are mentioned above is assumed to function during the alarm condition, in an event of fire, before the fire becomes as large as to affect its functioning. There is therefore no requirement to function when exposed to direct attack from fire.

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Elias Tsologiannis, R&D engineer

Eginio, Pieria, Greece 25/1/2018